


REV	NAME	DATE	DESCRIPTION

APPA LINEMAN RODEO - 2023
12KV/7.2KV SINGLE PHASE TRANSFORMER
JOURNEYMAN TRANSFORMER CHANGE OUT

DRAWN	TJG
DATE	10/19/22
CHKD	-
ENG APPV	-
SCALE	NTS
SHT	1 of 2
DWG. NO.	



ITEM	QTY.	STOCK NO.	DESCRIPTION	NOTE
a	1	0320029	15KV CUTOUT, OPEN TYPE 100AMP	
b	1	0320035	CUTOUT TUBE DISCONNECT BLADE 300A	
c	1	0250037	BRACKET INSULATOR 18" FIBERGLASS	
d	5	0170107	5/8" X 14" MACH. BOLT	
e	6	0170124	2" X 2" X 5/8" SQ. WASHER	
f	1	0230157	AMPACT STIRRUP #2	
g	1	0250059	HOT LINE CLAMP	
h	10	0200014	WIRE #4 BARE SOL CU SD	
i	2	1050973	CONNECTOR "C" CRIMP #6-4	
j	20	0200009	WIRE #2TPX AL W/#2 BARE NEUTRAL	
k	1	0240073	TIE DISTRIBUTION FOR F-NECK INSULATOR	
l	1	0270034	INSULATOR 15KV PIN TYPE F-NECK POLY	
m	1	0250183	PIN STEEL INSULATOR, FLARED BASE	
n	2	0170103	BOLT 5/8" x 10" GALV MACH.	
o	3	0260031	CONNECTOR TRANSFORMER STUD 4 POS #6-250	
p	2	0170048	INSULATOR WHITE-GRAY SECONDARY SPOOL-POLY	
q	2	0250085	CLEVIS SINGLE SPOOL DEADEND	
r	3	1042244	TERMINAL COMPRESSION PIN #1-2 STR 1/0 AL 6" PIN	

REV	NAME	DATE	DESCRIPTION	DRAWN	TJG
				DATE	10/19/22
				CHKD	-
				ENG APPV	-
<p align="center">APPA LINEMAN RODEO - 2023 12KV/7.2KV SINGLE PHASE TRANSFORMER JOURNEYMAN TRANSFORMER CHANGE OUT</p>				SCALE	NTS
				SHT	2 of 2
				DWG. NO.	





JM TRANSFORMER
CHANGE OUT