


REV	NAME	DATE	DESCRIPTION

DRAWN	---
DATE	10/15/21
CHKD	---
ENG APPV	N/A
SCALE	NTS
SHT	1 of 2
DWG. NO.	TFMR1




2022 Public Power Lineworkers Rodeo
 Apprentice Double Dead End Bell Change out

ITEM	QTY.	MAXIMO #	DESCRIPTION	NOTE
a	4	6816	clAMP DEAD END 1/o-4/o AcSR 2 BLT/cotter Pin	
b	8	8499	2' x 2' SQUARE WASHERS	
c	3	8689	BOLT DBL ARMING HOT DIP GALV ALL THREAD 20"	
d	2	6849	HOT LINE CLAMP	
e	4	820	INSULATOR 15KV DEADEND POLYMER	
f	2	9796	ARM WOOD 3-1/2' X 4-1/2' X 8' 6-PIN	
g	4	6553	INSULATOR 15KV PIN TYPE F-NECK PORCELAIN	
h	4	5487	TIE DISTRIBUTION FOR F-NECK INSULATOR NUT	
i	4	8470	EYE GALV 5/8 INCH	
j	2	870	BRACE 26" WOOD LT DUTY	
k	1	NIS	AMPACT 1/o	
l	1	6823	LINE STIRRUP 1/o	
m	1	17301	INSULATOR SPOOL 3 IN POLYMER	
n	2	1239	TIE SIDE PREFORM 1/o AcSR SNGL PAD	
o	1	6632	RACK PULLEY TY 1 POINT	
p	2	19466	SCREW 1/2' X 5' GALV. LAG	

NAME	DATE	DESCRIPTION	DRAWN

			DATE 10/15/21
			CHKD ---
			ENG APPV N/A
			SCALE NTS
			SHT 1 of 2
			DWG. NO. TFMR1

2022 Public Power Lineworkers Rodeo
Apprentice Double Dead End Bell Change out



REV