


REV	NAME	DATE	DESCRIPTION
1	---	10/15/21	4KV Cross Arm Changeout Specifications

DRAWN	---
DATE	10/15/21
CHKD	---
ENG APPV	N/A
SCALE	NTS
SHT	1 of 2
DWG. NO.	TFMR1

2022 Public Power Lineworkers Rodeo — 2022  
 JM 4KV Crossarm Change out CROSSARM CHANGE OUT



ITEM	QTY.	MAXIMO #	DESCRIPTION	NOTE
a	2	1930	PIN INSULATOR (LONG SHANK)	
b	5	8499	2" x 2" SQUARE WASHERS	
c	1	6632	RACK PULLEY TY 1 POINT	
d	3	6553	INSULATOR 15KV PIN TYPE F-NECK PORCELAIN	
e	1	8419	5/8" X 12" MACH BOL T	
f	1	19198	CROSSARM TANGENT 8FT FIBERGLASS GRAY	
g	1	17301	INSULATOR SPOOL 3 IN POLYMER	
h	1	1282	PIN POLE TOP 18 IN GALV	
i	3	5487	TIES PREFORM SNGL PIN CONSTRUCTION	

REV	NAME	DATE	DESCRIPTION	DRAWN	DATE
1	---	10/15/21	4KV Cross Arm Change out Material List	---	10/15/21
				CHKD	---
				ENG APPV	N/A
				SCALE	NTS
				SHT	1 of 2
2022 Public Power Lineworkers Rodeo JM 4KV CROSS ARM CHANGE OUT				DWG. NO.	TFMR1

